

# GOVERNMENT



## MOST CITED STANDARDS IN GOVERNMENT JANUARY 1, 2000 TO DECEMBER 31, 2000

RANK		STANDARDS CITED	NUMBER
1	1910.157	The requirements of this section apply to the placement, use, maintenance, and testing of <b>portable fire extinguishers</b> provided for the employees' use.	5
1	1910.305(g)	<b>Flexible cords</b> were used as a <b>substitute for fixed wiring</b> where not permitted. Flexible cords were not connected to devices and fittings so that <b>strain relief</b> was provided, which would have prevented pull from being transmitted to joints.	5
2	80-2(a),(b)	<b>General requirements were not met for all machines. Guarding</b> and <b>machines</b> designed for a fixed location were <b>not securely anchored</b> .	4
2	1910.303(g)	In locations where <b>electric equipment</b> would be exposed to physical damage, <b>enclosures</b> or <b>guards</b> were not arranged and of such strength as to <b>prevent damage</b> . <b>Live parts</b> of electrical equipment operating at 50 volts or more were <b>not guarded</b> by approved <b>cabinets</b> .	4
2	1910.304(e)	This section applies to <b>overcurrent protection</b> of circuits rated 600 volts, nominal or less. <b>Overcurrent devices were not readily accessible</b> to each employee or authorized building management personnel.	4